

Minutes of the Consolidated Board of Health Meeting held on December 16, 2014 at the Town Center, Old Post Road, Lake George, New York commencing at 3:00 p.m.

Members Present: Dennis Dickinson, Chairman
Fred Austin

Absent: Mayor Blais

Also Present: Patty Schuster, Keith Osborne, Garry Robinson, Kathy Bozony

Chairman Dickinson called the meeting to order at 3:00 p.m.

KAEICHELE

Garry Robinson was present representing the applicant. This property is located on Sagamore Street. This is a failed septic system. The septic system is a dry well with infiltrators coming out of the drywell. This will be 100 feet from his well.

This is an Elgen System. It was suggested that he put risers to grade on the inlet and the outlet.

A motion was made by Supervisor Dickinson and seconded by Fred Austin to approve with the conditions that the inlet and outlet of the septic tank be extended; The Town of Lake George shall be given at least 48 hours notice prior to construction for monitoring and observation by the Zoning Enforcement Officer and the applicant's engineer shall certify that the plan meets all requirements.

All in favor.

Motion carried.

A motion was made by Fred Austin and seconded by Supervisor Dickinson to adjourn the meeting at 3:10 p.m.

Respectfully submitted,

Patty Schuster
Clerk of the Board