

# **CONSOLIDATED BOARD OF HEALTH**

**TOWN/VILLAGE OF LAKE GEORGE**

**20 OLD POST ROAD**

**LAKE GEORGE, NY 12845**

**518 668-5131**

## **A G E N D A**

**September 27, 2018**

**3:00 p.m.**

### **PUBLIC HEARINGS**

#### **1. CBOH #2-2018: Jephson Hilary**

Code Reference: Ch.115-6(E)(1)(b)

Applicant proposes to replace an outdated existing septic system with a new engineered-designed septic system to accommodate the five (5) bedrooms single family dwelling/cottage.

The relief requested is for vertical separation/depth to bedrock, where 72" (6') is required for a conventional absorption bed and 54" (4'6") is proposed.

For property located at 11 Hill Drive, Lake George, NY 12845; Tax Map ID# 251.07-1-1.1.